



CAMERON COUNTY PURCHASING

1100 E. Monroe St,
Brownsville, Texas 78520
(956) 544-0871 Fax: (956) 550-7219

ADDENDUM No. 2 - PAGE 1 of 1

Date out: March 21, 2019

CAMERON COUNTY CDBG COLONIA CORONADO W/W IMPROVEMENTS PROJECT

BID No. 190302

DEADLINE: MARCH 26, 2019

(IN ORDER TO AVOID DISQUALIFICATION – ALL ADDENDA MUST BE SIGNED AND RETURNED BY DEADLINE AND INCLUDED IN THE SEALED BID PACKAGE SUBMITTED)

To Respondents of Record:

This Addendum is an amendment to the proposed plans and specifications, and shall be made part of and included in the Contract Documents. Acknowledge receipt of this addendum by signing and including this addendum with the sealed bid package.

Clarifications

Q. Is the contract time 90 or 180 days?

A. The contract is to be substantially complete in 240 Calendar days.

Q. On sheet 11 of 14, plans show duplex houses (3710 A & B, and 4001 A & B), are we to address this with two 4" PVC Lines as item No. 2 states? Or Can we put in place a 6" PVC pipe connection to the main line and then divide the line to two 4" one for each house?

A. This structure will be connected with a single 4" yard-line.

Q. On sheet 11 of 14, plans show house 5964 on Maverick Rd but it's not hashed or filled, are we to connect this house also?

A. No, this house is not part of the project.



Company Name _____ Phone # _____

Vendor Signature _____ Date _____